

## INFORMATION SHEET

The NF mark guarantees the quality of this item in accordance with technical certification rules NF 536

See marking requirements acc. to type of device and statement in §2.4.2



AIR CLEANERS

[www.marque-nf.com](http://www.marque-nf.com)

N° 21.06.011

### IN COMPLIANCE WITH THE SPECIFICATIONS DEFINED BY THE CERTIFICATION RULES OF THE NF 536 MARK

#### CERTIFIED CHARACTERISTICS<sup>(1)</sup>:

	minimum speed	intermediate speed	maximum speed
Air circulation flow rate (m <sup>3</sup> /h)	57 m <sup>3</sup> /h	/	93 m <sup>3</sup> /h
Absorbed electrical power (W)	200 W	/	730 W
Sound power level (dB[A])	78 db(A)	/	87 db(A)

	Initial purified air flow rate (m <sup>3</sup> /h)	Recommended room area (m <sup>2</sup> )
Inert particles	between 0 and 90	between 0 and 9

If applicable:

Gases	between 7 and 40	between 1 and 8
Microorganisms	66	3.3
Allergens	60	3

Maximum purified air flow rate value/Absorbed electrical power (m <sup>3</sup> /h/W)	0,127
--	-------

(1) For more information, visit the [www.eurovent-certification.com](http://www.eurovent-certification.com) web site.

#### OPERATING AND MAINTENANCE ADVICE

Please see the manual enclosed with the device and the safety data plate on the device

Item reference and batch or serial number: see product

If you are unsatisfied, first consult:  
HYLA EVOLUTION

12 Rue Thomas Edison, 77100 Meaux, France

If there is still a problem, you can write to the certification body:

EUROVENT CERTITA CERTIFICATION SAS

48/50 rue de la Victoire

F- 75009 PARIS